



THE CORPORATION OF THE TOWNSHIP OF FARADAY

Addendum #2

July 27, 2022

Re: Request for Quotation - #FD02-2022 – Renovations at Township Fire Halls

Addendum #1 for the above noted Request for Quotation is being issued for clarification purposes.

LOWER FARADAY ROAD FIRE HALL

Question 1. What is the desired wall assembly for the new R20 insulated wall in the large bay? **Rigid Foam.**

Question 2. What is the desired finish on the newly insulated wall in the large bay? **Plywood and Paint.**